

INSERT PAGES  
IBC CHAPTER 7

To be inserted between pages 110 & 111.

**Comm 62.0716 Ducts and air-transfer openings. (1) PENETRATIONS OF SHAFT ENCLOSURES.** This is a department exception to the requirements in IBC section 716.5.3: Smoke dampers are not required in ducts that are used in the exhaust portion of laboratory ventilating systems which are designed and installed in accordance with NFPA 45.