

INSERT PAGES
IBC CHAPTER 9

To be inserted between pages 188 & 189.

Comm 62.0907 Fire alarm and detection systems. (7) EMPLOYEE WORK AREAS.
Substitute the following wording for the requirements in IBC section 907.9.1.2: Where employee work areas have audible alarm coverage, the alarm system shall be designed so that visible notification appliances can be integrated into the system.